

State Water Resources Control Board

June 30, 2015

CERTIFIED MAIL
NO. 7014 2120 0000 5508 3484

Mr. Lewis Broschard
Assistant Chief
Contra Costa County Fire Protection District
2010 Geary Road
Pleasant Hill, California 94523

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS
LOCATED AT CONTRA COSTA COUNTY FIRE PROTECTION DISTRICT,
STATION #09, 209 CENTER AVENUE, PACHECO**

Dear Mr. Broschard:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on June 4, 2015, pursuant to authority under Health and Safety Code, chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to Health and Safety Code (H&SC), chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Facility and Tank Information (A&B Forms) - Piping system is conventional suction and tank manufacturer needs to be updated.	Diesel	June 4, 2015	June 11, 2015	23 CCR 2711(a)
2	Failure to Maintain Monitoring Plan - Update person having responsibility, pipe monitoring, leak sensor model #, Monthly SIR should be "No," and recordkeeping section for Tank Integrity Testing Results should say "No." Include a site map with plan.	Diesel	June 4, 2015	June 11, 2015	23 CCR 2711(a)(9)
3	Failure to Maintain Release Response Plan - Update person having responsibility.	Diesel	June 4, 2015	Ongoing	23 CCR 2632(d)(2)

No.	Violation	Tank	Start Date	Stop Date	Regulation
4	Failure to Maintain Monitoring or Testing Records On-site - Annual Monitoring Certification for 2012 and 2014 and Spill Containment Structures test for 2012 were not available at time of inspection.	Diesel	June 4, 2015	Ongoing	H&SC 25293; 23 CCR 2712(b)
5	Failure to Provide DO Training - The employee training record performed by the DO is dated March 27, 2014.	Diesel	April 1, 2015	Ongoing	23 CCR 2715(f)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Contra Costa County Health Services within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Ms. Rebecca Green
UST Enforcement Unit
State Water Resources Control Board
1001 I Street, 19th Floor
Sacramento, California 95814
rebecca.green@waterboards.ca.gov


Local CUPA

Ms. Alexandra McMullen
Supervising Administrative Support
Contra Costa County Health Services
Department
4585 Pacheco Boulevard, Suite 100
Martinez, California 94553
alexandra.mcmullen@hsd.cccounty.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me by telephone at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: (see next page)

cc: *(via email only)*

Ms. Alexandra McMullen
Supervising Administrative Support
Contra Costa County Health Services Department
alexandra.mcmullen@hsd.cccounty.us

Mr. Adam Springer
Hazardous Materials Specialist II
Contra Costa County Health Services Department
Adam.Springer@hsd.cccounty.us